

Certificate No.: H2 2019  
 Date of Test: 2019/05/16  
 Applicant: M Props  
 Description: H2 Camlok Prop



## TEST RESULTS

The results of the compression test carried out on the H2 Camlok Prop are summarised in Table 1.

Test No	Test height (m)	Maximum load carried (kN)	Mode of failure
1	0.95	214.47	Hole Elongation
2	1.12	239.46	Hole Elongation
3	1.40	239.03	Hole Elongation

