

Certificate No.: H4 2019
Date of Test: 2019/05/16
Applicant: M Props
Description: H4 Camlok Prop



TEST RESULTS

The results of the compression test carried out on the H4 Camlok Prop are summarised in Table 1.

Test No	Test height (m)	Maximum load carried (kN)	Mode of failure
1	1.40	225.98	Hole Elongation
2	1.80	228.13	Hole Elongation
3	2.25	225.70	Hole Elongation

